

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20140723-E57766  
**Report Reference** E57766-A7-UL  
**Issue Date** 2014-JULY-23

**Issued to:** EUROTHERM LTD  
FARADAY CLOSE  
DURRINGTON  
WORTHING  
WEST SUSSEX  
BN13 3PL UNITED KINGDOM

**This is to certify that  
representative samples of**


PROCESS CONTROL EQUIPMENT, ELECTRICAL  
Temperature Controller: Temperature Controllers, series: 2604,  
2704, 3504, 3508, followed by VH or VL, followed by other  
suffixes

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 61010-1 & CAN/CSA-C22.2 No. 61010-1: ELECTRICAL  
EQUIPMENT FOR MEASUREMENT, CONTROL, AND  
LABORATORY USE - Part 1: General Requirements

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

