

CERTIFICATE OF COMPLIANCE

Certificate Number UL-CA-L86160-41-52403102-2
Report Reference E86160-20130425
Date 4-Jul-2022

Issued to: EUROTHERM AUTOMATION SAS
6 CHEMIN DES JONCS
BP 55 DARDILLY CEDEX 69574
France

This is to certify that representative samples of NRNT7 - Switches, Industrial Control Certified for Canada
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: CSA C22.2 NO. 60947-4-1, 2nd Ed., Issue Date: 2014-04-04, Revised 2018-05

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number UL-CA-L86160-41-52403102-2
Report Reference E86160-20130425
Date 4-Jul-2022

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model	Category Description
EPack, followed by -, maybe followed by Lite, followed by 1PH/, 2PH/ or /3PH, followed by 16, 25, 32, 40, 50, 63, 80, 100 or 125, followed by A, followed by /24V or /500V.	Industrial Control Switches



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number UL-US-L86160-11-52403102-2
Report Reference E86160-20130425
Date 4-Jul-2022

Issued to: EUROTHERM AUTOMATION SAS
6 CHEMIN DES JONCS
BP 55 DARDILLY CEDEX 69574
France

This is to certify that representative samples of NRNT - Switches, Industrial Control
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 60947-4-1, 3rd Ed., Issue Date: 2014-04-04, Revision Date: 2017-10-17, UL 60947-1, 5th Ed., Issue Date: 2013-07-31, Revision Date: 2019-05-06

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




CERTIFICATE OF COMPLIANCE

Certificate Number UL-US-L86160-11-52403102-2
Report Reference E86160-20130425
Date 4-Jul-2022

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Model	Category Description
EPack, followed by -, maybe followed by Lite, followed by 1PH/, 2PH/ or /3PH, followed by 16, 25, 32, 40, 50, 63, 80, 100 or 125, followed by A, followed by /24V or /500V.	Industrial Control Switches



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

